



"RE-BUILDING THE CITY'S WATER SYSTEMS FOR THE 21ST CENTURY"

Sewerage & Water Board of NEW ORLEANS

625 ST. JOSEPH STREET
NEW ORLEANS, LA 70165 • 504-529-2837 OR 52-WATER
www.swbno.org

Addendum No. 2

Date: 9/2/2021

Your reference is directed to **Contract Number: 30238** for restoration of gravity flow sanitary sewers by excavation and replacement from manhole to manhole, CIPP lining from manhole to manhole, CIPP lining of service laterals and point repairs at various sites throughout the City of New Orleans which was scheduled to open at 11:00 a.m. CST on September 10, 2021 for SWBNO Networks Department.

This addendum provides for the following:

1. The bid opening date is rescheduled to **September 27, 2021 at 11:00 a.m. CST.**
2. Responses to vendor questions received before the inquiry deadline of September 1, 2021 at 5:00 p.m.

Response to vendor questions:

1. I didn't see any drawings for this project S&WB 30238.
Since this is a maintenance contract, only standard drawings apply to this contract. Standard drawings can be provided upon request.
2. What is the LF and diameter of the lateral lining?
The linear feet of the lateral lining will depend on the length of the particular lateral for the address. The first 5 LF will be paid with a bit line item as an EA quantity and any additional length beyond 5 LF will be paid under a separate line item per foot. The diameter for the lateral lining will be 6 inches.
3. In the specs we could not specify a MIL thickness for the new CIPP Liner to be installed. Please specify as this would increase the cost of the liner greatly especially on the larger diameter liner.
The required thickness for the CIPP liner is given in a table in Section 9 - Part 2.01.

The above revisions shall be incorporated in and take precedence over any conflicting part of the original proposal documents. This addendum is hereby officially made a part of the referenced proposal.

Receipt of this addendum shall be acknowledged by inserting its number and date in the space provided in the Form of Proposal and by attaching it to the specifications.

This addendum consists of one (1) page.

*** END OF ADDENDUM ***